

# Williams Visit Report

**School:** Turner Elementary School

**Visit Date:** 8/17/2017

**Uniform Complaint Policies:** In Compliance

**SARC:** In Compliance

**Textbooks:**

**Visitation:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies – sufficient
4. Science: - sufficient
5. ELD – sufficient

**Document Review:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient
- 6.

**GOOD 94.06%**

**Pre-school portables are in extreme disrepair.**

**Facility Issues that affect the overall rating:**

1. Mechanica/HVAC
  - a. Pre-school Portables - Unsecured vent covers
2. Electrical
  - a. Library – inop lights
3. Restrooms
  - a. A-wing girls’ restroom – inop toilet
4. Sinks and Fountains
  - a. Pre-school portables – inop water faucet
5. Structural damage
  - a. Pre-school portables –
    - i. Damaged siding exposing pipe and hose spigot
    - ii. Exposed nails
  - b. Portables 3-5 – Paint in disrepair; loose flashing

# Williams Visit Report

6. Roofs
  - a. Pre-school portables – Leaking gutter
7. Playgrounds / school grounds
  - a. Pre-school portables – unkempt lawn; damaged water valve cover
  - b. Grounds: front of school – unkempt landscaping
  - c. Grounds: asphalt play areas – unkempt surface (trip/fall hazard); ball wall in disrepair
  - d. Grounds: Main courtyard – uneven walkway; unkempt landscaping
8. Windows/doors
  - a. Pre-school portables –rusting doors