

# Williams Visit Report

**School: Ygnacio Valley High School**

**Visit Date: 8/29/17**

**Uniform Complaint Policies: In Compliance**

**SARC: In Compliance**

## **Textbooks:**

### **Document Review:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient
6. Foreign Language – sufficient
7. Health – sufficient

### **Visitation:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD – sufficient
6. Foreign Language – sufficient
7. Health - sufficient

**Overall Facilities Rating: GOOD 93.05%**

**Teachers were well prepared and welcoming!**

## **Facility issues which affect the overall rating:**

1. Interior Surfaces
  - a. Boys' locker room – missing/damaged ceiling tile(s)
  - b. Room 208 – unsecured bookcase(s)
  - c. Room 312 – damaged bookcase(s)
  - d. Room 410– unsecured bookcase(s)
  - e. Room 503 – missing pencil sharpener cover(s)
  - f. Room 510 – missing pencil sharpener cover(s)
  - g. Room 803 – unsecured bookcase(s)
2. Electrical
  - a. Library – inop light(s)

# Williams Visit Report

- b. Boys' locker room – missing diffusers
  - c. Room 208 – cord management
  - d. Room 308 – inop light(s)
  - e. Room 309 – cord management
  - f. Room 402– cord management; inop light(s)
  - g. Room 403 – missing outlet cover(s)
  - h. Room 406 – inop light(s)
  - i. Room 409 – inop light(s)
  - j. Room 502– cord management; inop light(s)
  - k. Room 503 – inop light(s)
  - l. Room 505 – cord management
  - m. Room 506 – cord management
  - n. Room 510 – cord management, inop light(s)
  - o. Room 511 – cord management
  - p. Room 803 – cord management
  - q. Room 804 – cord management
  - r. Room 805 – cord management
3. Restrooms
- a. 200 bldg. boys' restroom – damaged seat cover dispenser(s)
  - b. 600 bldg. girls' restroom – inop toilet(s); inop paper towel dispenser(s)
  - c. Girls' locker room – damaged toilet seat(s)
4. Sinks and Fountains
- a. 100 bldg. boys' restroom – inop faucet(s)
  - b. 600 bldg. boys' restroom – damaged faucet(s)
  - c. Boys' locker room – damaged faucet(s)
5. Fire Safety
- a. Room 503 – missing fire extinguisher
  - b. Room 505 – missing fire extinguisher
  - c. Room 510 – missing fire extinguisher
  - d. Room 702 – missing fire extinguisher
  - e. Room 803 – missing fire extinguisher
  - f. Room 805 – missing fire extinguisher
6. Playgrounds / school grounds
- a. General grounds – unkempt landscaping (minor)
7. Windows/doors
- a. 100 bldg. hallway – missing/damaged louvres
  - b. 600 bldg. hallway – missing/damaged louvres