

# Williams Visit Report

**School: Pinole Middle School**

**Visit Date: 9/7/2017**

**Uniform Complaint Policies: In Compliance**

**SARC: In Compliance**

**Textbooks:**

**Document Review:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient
6. Foreign Language – sufficient

**Visitation:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient
6. Foreign Language – sufficient

**Overall Facilities Rating: GOOD 96.07%**

**Nice facilities, clean, neat and in good repair.**

**Facility issues which affect the overall rating:**

1. Mechanical / HVAC
  - a. B-19 boys' restroom – inop fan
  - b. B-19 girls' restroom – inop fan
2. Interior Surfaces
  - a. Bldg. A hallways – wall in disrepair
  - b. Bldg. B lower hallways – missing glass in cabinet; damaged ceiling tile(s)
  - c. Library – damaged carpet(s)
  - d. Bldg. B upper hallways – damaged exit sign; damaged ceiling tile(s); damaged star step (s) non-skid strips in disrepair; rubber edges of steps in disrepair.
  - e. B22 – damaged ceiling tile(s)
  - f. BSL3 – unsecured shelving

# Williams Visit Report

3. Electrical
  - a. A-10 boys' restroom – missing light switch
4. Restrooms
  - a. A-10 boys' restroom – missing toilet paper dispenser
  - b. A-13 boys' restroom – missing soap dispenser holder
5. Fire Safety
  - a. Bldg. B lower hallways – missing case over fire light
  - b. A15 – missing fire extinguisher
  - c. A16 – missing fire extinguisher
  - d. B21 – missing fire extinguisher
  - e. B22 – missing fire extinguisher
6. Roofs
  - a. B20 – damaged roof tiles
7. Windows/doors
  - a. A-11 girls' restroom – damaged door(s)
  - b. B-19 boys' restroom - damaged door stops